


REPORT TO BE SENT TO:


 Telford & Wrekin Council (Stoney Hill)
 Highways Transport & Engineer
 Granville House
 Telford Shropshire
 TF2 7RA

ANALYSIS REPORT

SAMPLING POINT CODE 9977979


SAMPLE FROM: Telford & Wrekin Council (Stoney Hill)
 Stoney Hill
 Lightmoor
 Telford Shropshire
 TF4 3QQ

DESCRIPTION: leachate

SAMPLE NUMBER: 1355631
 SAMPLE DATE: 08/08/2022 SAMPLE METHOD: Spot
 SAMPLE TIME: 10:05:00 SAMPLE REASON: TE Control Sample
 CHARGEABLE N TAKEN BY : 384

DETERMINAND	RESULT VALUE	UNITS	CONSENT LIMITS
Iron (total) as Fe (mg/l)	6.2	mg/l	IM 0: 25
Aluminium (total) as Al (mg/l)	<0.075	mg/l	IM 0: 2
Chromium (total) as Cr (mg/l)	0.011	mg/l	
Copper (total) as Cu (mg/l)	<0.018	mg/l	IM 0: 1
Lead (total) as Pb (mg/l)	<0.0030	mg/l	
Nickel (total) as Ni (mg/l)	0.048	mg/l	
Zinc (total) as Zn (mg/l)	<0.060	mg/l	IM 0: 2
Sulphide as S (mg/l)	<0.01	mg/l	IM 0: 1
Sulphate Filtered	<4.40	mg/l	IM 0: 1000
Sampling Access (TE site test)	P		
PH	9.0	pH_unit	IM 6: 10
METHANE SOLUBLE	0.017	mg/l	IM 0: .14

REPORT DATE: 22/08/22

 ENQUIRIES REGARDING THIS REPORT SHOULD
 BE MADE TO:
 

SIGNED:

DATE: