

REPORT TO BE SENT TO:

[REDACTED]  
 Telford & Wrekin Council (Stoney Hill)  
 Highways Transport & Engineer  
 Granville House  
 Telford Shropshire  
 TF2 7RA

## ANALYSIS REPORT

-----

SAMPLING POINT CODE 9980229

SAMPLE FROM: Telford & Wrekin Council (Stoney Hill)  
 Stoney Hill  
 Lightmoor  
 Telford Shropshire  
 TF4 3QQ

DESCRIPTION: leachate

SAMPLE NUMBER: 1484134  
 SAMPLE DATE: 02/09/2024      SAMPLE METHOD: Spot  
 SAMPLE TIME: 07:00:00      SAMPLE REASON: Routine Program  
 CHARGEABLE      Y      TAKEN BY      :      914

-----

DETERMINAND	RESULT VALUE	UNITS	CONSENT LIMITS
SS	91.0	mg/l	IM 0: 400
COD 1h settled	381	mg/l	IM 0: 1000
Visual Quality (site test)	P		
Sampling Access (TE site test)	P		
VISIBLE OIL (TE FIELD/ SITE TEST)	P		
AMMONIACAL NITROGEN AS N	266	mg/l	IM 0: 500

-----

REPORT DATE: 13/09/24

ENQUIRIES REGARDING THIS REPORT SHOULD  
BE MADE TO:

[REDACTED]  
 [REDACTED]  
 [REDACTED]

SIGNED:

DATE: