

Constraints	Aluminium, Total as Al	Ammoniacal Nitrogen as N	COD (Total)	Copper, Total as Cu	Methane, Dissolved	pH	Total Suspended Solids	Sulphate as SO4	Sulphide as S	Visible Oil	Zinc, Total as Zn	Sampled By
Limit Value	2	500	1500	1	0.14	6.0-10.0	1000	1000	1	None	2	
Units	mg/l	mg/l	mg/l	mg/l	mg/l	pH Units	mg/l	mg/l	mg/l	None	mg/l	
Minimum Detection Value	<0.1	<0.41		<0.009	<0.01			<4.4	<0.02			
Sample Data Received												
22/12/2016		0.41	36			7.7	4					
30/07/2018	0.4	0.41	99	0.011	0.01	7.4	274	34.7	0.312	None	0.237	ALS
21/09/2020	0.0236	0.2	35.3	0.000962	0.0109	7.01	2	82	0.0143	None	0.0165	Veolia
17/12/2020	0.451	0.021	34.5	0.00218	0.00101	7.05	4.05	35.6	0.01	None	0.0353	Veolia
04/01/2021	0.218	0.2	19	0.00408	0.0123	7.31	3.55	41.2	0.01	None	0.0584	Veolia
07/04/2021	0.121	0.2	41.9	0.001	0.00366	7.47	18.6	50.3	0.0162	Absent	0.0218	Veolia
06/07/2021	0.01	0.2	7	0.001	0.00149	7.68	4.3	26.7	0.0852	Absent	0.0173	Veolia
04/10/2021	0.0171	0.2	42.1	0.001	0.0116	7.5	6.2	21.6	0.0232	Absent	0.0126	Veolia
06/01/2022	0.0281	<0.2	30.9	0.00271	0.00237	7.67	<2	44.6	<0.01	Absent	0.0291	Veolia
06/04/2022	0.01	0.1	57	<0.001	<0.02	7.4	26	42	<0.02	Absent	0.03	Veolia
05/07/2022	0.01	0.05		<0.001	<0.02	7.8	6	27	0.06	one visib	0.007	Veolia
05/10/2022	0.99	1.5		<0.01	0.04	7.1	362	93	3.58	one visib	0.053	Veolia
04/01/2023	0.16	0.03		0.002	<0.02	7.1	6	60	0.07	one visib	0.112	Veolia
05/04/2023	0.02	0.02		0.001	<0.02	7.6	<5	68	0.03	Absent	0.027	Veolia
12/07/2023	<0.01	0.2		<0.001	<0.02	7.2	16	35	0.12	Absent	0.015	Veolia
05/10/2023	<0.01	0.13		<0.001	<0.02	7.5	<5	22	0.05	Absent	0.015	Veolia

Constraints	Aluminium, Total as Al	Ammoniacal Nitrogen as N	COD (Total)	Copper, Total as Cu	Methane, Dissolved	pH	Total Suspended Solids	Sulphate as SO <sub>4</sub>	Sulphide as S	Visible Oil	Zinc, Total as Zn	Sampled By
Limit Value	2	500	1500	1	0.14	6.0-10.0	1000	1000	1	None	2	
Units	mg/l	mg/l	mg/l	mg/l	mg/l	pH Units	mg/l	mg/l	mg/l	None	mg/l	
Minimum Detection Value	<0.1	<0.41		<0.009	<0.01			<4.4	<0.02			
Sample Data Received												
22/12/2016		0.41	39			7.2	14					
30/07/2018	0.1	0.41	32	0.009	0.022	7.2	26	98.7	0.02	None	0.018	ALS
21/09/2020	0.039	0.2	55.9	0.00119	0.00182	7.25	3.3	28.8	0.01	None	0.0165	Veolia
04/01/2021	0.462	0.2	119	0.00613	0.001	6.42	60.5	45.8	0.01	None	0.0916	Veolia
06/07/2021	51	0.2	13.4	<0.001	0.00147	7.57	4.65	55.7	<0.01	Absent	27	Veolia
06/01/2022	0.148	<0.2	22.1	0.00406	0.00147	7.22	4.15	85.5	<0.01	Absent	0.0349	Veolia
04/01/2023	0.22	0.06		0.003	<0.02	7	<5	114	0.03	one Visib	0.117	Veolia

Constraints	Aluminium, Total as Al	Ammoniacal Nitrogen as N	COD (Total)	Copper, Total as Cu	Methane, Dissolved	pH	Total Suspended Solids	Sulphate as SO4	Sulphide as S	Visible Oil	Zinc, Total as Zn	Sampled By
Limit Value	2	500	1500	1	0.14	6.0-10.0	1000	1000	1	None	2	
Units	mg/l	mg/l	mg/l	mg/l	mg/l	pH Units	mg/l	mg/l	mg/l	None	mg/l	
Minimum Detection Value	<0.1	<0.41		<0.009	<0.01			<4.4	<0.02			
Sample Data Received												
30/07/2018	0.3	0.46	116	0.009	0.06	7.1	116	64.2	0.062	None	0.246	ALS
21/09/2020	0.0236	0.2	40.3	0.000992	0.00102	7.11	2.25	80.2	0.0236	None	0.0205	Veolia
17/12/2020	0.409	0.017	26.5	0.00348	0.00248	7.03	6.2	52.6	0.01	None	0.0848	Veolia
04/10/2021	0.016	0.2	45.5	0.001	0.0014	7.3	4.25	46.7	0.161	Absent	0.0357	Veolia
06/04/2022	0.06	0.3	30	<0.001	<0.02	7.1	<5	71	<0.02	Absent	0.048	Veolia
05/07/2022	<0.01	0.02		<0.001	<0.02	7.5	<5	112	0.02	one visib	0.003	Veolia
05/10/2022	0.03	0.02		<0.001	<0.02	7.3	85	47	0.3	one visib	0.11	Veolia
05/04/2023	0.06	0.04		<0.001	<0.02	7.2	<5	107	0.04	Absent	0.066	Veolia
12/07/2023	0.01	0.12		<0.001	<0.02	7.2	5	107	0.03	Absent	0.018	Veolia
05/10/2023	<0.01	0.8		<0.001	<0.02	7.3	19	58	0.16	Absent	0.037	Veolia