

Sample Data Received	Aluminium mg/l	Ammoniacal Nitrogen mg/l	COD mg/l	Copper mg/l	Dissolved Methane mg/l	pH	Total Suspended Solids mg/l	Sulphate mg/l	Sulphide mg/l	Visible Oil	Zinc mg/l	Sampled By
<b>22/12/2016</b>		0.41	36			7.7	4					
<b>30/07/2018</b>	0.4	0.41	99	0.011	0.01	7.4	274	34.7	0.312	None	0.237	ALS
<b>21/09/2020</b>	0.0236	0.2	35.3	0.000962	0.0109	7.01	2	82	0.0143	None	0.0165	Veolia
<b>17/12/2020</b>	0.451	0.021	34.5	0.00218	0.00101	7.05	4.05	35.6	0.01	Absent	0.0353	Veolia
<b>04/01/2021</b>	0.218	0.2	19	0.00408	0.0123	7.31	3.55	41.2	0.01	Absent	0.0584	Veolia
<b>07/04/2021</b>	0.121	0.2	41.9	0.001	0.00366	7.47	18.6	50.3	0.0162	Absent	0.0218	Veolia
<b>06/07/2021</b>	0.01	0.2	7	0.001	0.00149	7.68	4.3	26.7	0.0852	Absent	0.0173	Veolia
<b>04/10/2021</b>	0.0171	0.2	42.1	0.001	0.0116	7.5	6.2	21.6	0.0232	Absent	0.0126	Veolia
<b>06/01/2022</b>	0.0281	0.2	30.9	0.00271	0.00237	7.67	2	44.6	0.01	Absent	0.0291	Veolia
<b>06/04/2022</b>	0.01	0.1	57	0.001	0.02	7.4	26	42	0.02	Absent	0.03	Veolia